

James Nykaza  
Chief Fire Marshal



Steve Forbes  
Assistant Fire Marshal

## City of Humble Fire Marshal's Office

110 W. Main Street, Humble, Texas, 77338  
281-446-4928

# Fire Lane - Signs and Curb

**IFC 2018- D103.6 Signs.** Where required by the *fire code official*, fire apparatus access roads shall be marked with permanent NOPARKING—FIRE LANE signs complying with Figure D103.6. **Signs shall have a minimum dimension of 12 inches (305 mm) wide by 18 inches (457 mm) high and have red letters on a white reflective background.** Signs shall be posted on one or both sides of the fire apparatus road as required by Section D103.6.1 or D103.6.2.



**City Ordinance- Sec. 18-77. - Designation, posting, closing of fire lanes; parking in fire lanes prohibited; issuance of summons or notice.**

(c) Upon the designation of the fire lane pursuant to this section, the fire marshal shall give notice of such designation to the owner of such shopping centers, hospitals, apartment houses, assembly buildings, schools or businesses, directing the owner to establish the fire lanes to the following specifications: **All curbs must be painted red and be conspicuously and legibly marked with the warning "FIRE LANE—TOW AWAY ZONE" in white letters at least three inches tall, at intervals not exceeding 50 feet.** If a curb does not exist, one permanent sign shall be posted in the approximate center of a fire lane no more than ten feet in length. Fire lanes more than ten feet in length shall be marked by a permanent sign posted at both ends of the fire lane as well as a spacing of one sign every 30 feet of the length of the fire lane. Parking surface painting and signs shall be of a standard size and color, as well as standard lettering and sign mounting conforming to pattern drawings or samples of the same. Such pattern drawings or samples shall be obtained from the fire marshal division of the city.

**FIRE LANE TOW AWAY ZONE**